

Certificate of Product Approval

Certificate Number: 1075g

Issue: 01

Charter Global Limited

1 Darwin Close
Reading
Berkshire
RG2 0TB

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product

Obexion ID5
security shutters

Standard

LPS 1175: Issue 8

Requirements and testing procedures for the LPCB certification and listing of intruder resistant building components, strongpoints, security enclosures and free-standing barriers

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Chris Hunt
Verifier

23 August 2023
Date of Issue

23 August 2023
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1075g Charter Global Limited

Issue: 01

Security Shutters

Product Name	Type	Minimum Structural Opening Height (m)	Maximum Structural Opening Height (m)	Minimum Structural Opening Width (m)	Maximum Structural Opening Width (m)	Locking Devices	Security Rating	LPCB Ref No.
Obexion ID5	Internally face fixed security shutter incorporating solid lath	1.0	8.0	1.75	8.0	Two manual slide bolts or two 24V solenoid bolts	E10 (SR5)	1075g/01

Approved Installation Configurations

Product Name	Type	Substrate			
		Reinforced Brickwork	Reinforced Blockwork	Reinforced Concrete	Steelwork
Obexion ID5	Internally face fixed security shutter	✓	✓	✓	✓

Notes:

- The security rating only applies to the shutters when installed and operated in accordance with the documents titled 'Obexion ID Installation Instructions Revision 2' and 'Obexion Specialist Security Systems: Operation and Maintenance Manual. Original Instructions Revision 1'. The installation shall be direct to the substrate and not via intermediate substrates, such as plasterboard.
- The locking devices are fitted to the internal face of the product. Certification does not cover the use of locking devices other than those listed above. Utilisation of unlisted locking devices may affect the level of security offered by the shutter.

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Chris Hunt
Verifier

23 August 2023
Date of Issue

23 August 2023
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

